



3+N+PE st. 50Hz 400/230V / TN-C-S



POMOCNÉ OBVODY



05	05/1	55	56	57	58	59	60	61	62	63	64
WL05	WL05/1	WL55	WL56	WL57	WL58	WL59	WL60	WL61	WL62	WL63	WL64
CNY-1 5x6	CNY-0 2x1.5	CNY-1 3x1.5	CNY-1 3x2.5	CNY-1 3x2.5	CNY-1 3x1.5	CNY-1 3x2.5	CNY-1 3x2.5	CNY-1 5x2.5	CNY-1 3x2.5	CNY-1 3x1.5	CNY-1 3x2.5



Rozváděč horní Rozváděč horní Osvětlení m.č. 3.07 Zásuvky m.č. 3.07, Zásuvky m.č. 3.09 Zásuvka m.č. 3.09 Zásuvky m.č. 3.09 Bojler m.č. 3.07 Sporák m.č. 3.09 Zásuvky m.č. 3.08 Rezervo Rezervo

- 3,10 3,08, 3,10

- myčka

- lednice

- linka, odsavac

- púchka, sušiko

Vypracoval:	Čurda Jiri	AKCE:	Rekonstrukce budovy bývalé pošty na byty	Investor:	Obec Český Rudolec, Český Rudolec 123	Zak.číslo:	24 005 03	A.K.:	
Kontroloval:			Český Rudolec Elektroinstalace	Obsah:		Změna/Datum:		V.č.:	
Datum	: 03.08.2024					Měřtko:	N	D.1.4.1_7	Lišt: 2